

COAL INDIA LIMITED

MARKETING & SALES DIVISION

COAL STOCK POSITION OF POWER PLANTS HAVING COAL LINKAGE WITH COAL INDIA LIMITED & SCCL AS PER CEA REPORT

| Region/State | Name of Thermal Power Station | Specific Coal Consumption (Kcal/kg) | Consumption for last 07 days (Average)* | Requirement @ 55% PLF | Requirement for the day (In '000 Tonnes') (Higher of D and E) | Actual Stock (In 000 Te) | | | In Days | Status of Criticality as per "New methodology for monitoring of coal stock at coal based thermal power plants" dated 08.11.2017 Critical(*)/Supercritical(**) | Reasons for not considering the plant under critical/super critical category inspite of plant carrying low stock |
|--------------------------|-------------------------------|-------------------------------------|---|-----------------------|---|--------------------------|--------|-------|---------|---|--|
| | | | | | | Indigenous | Import | Total | | | |
| A | B | C | D | E | F | G | H | I | J=(I/F) | | |
| Haryana | | | | | | | | | | | |
| 1 | INDIRA GANDHI STPP | 0.66 | 4.3 | 13.11 | 12.1 | 285.6 | 67.1 | 352.7 | 29 | | |
| 2 | MAHATMA GANDHI TPS | 0.61 | 9.4 | 10.59 | 9.6 | 217.6 | 54.3 | 271.9 | 28 | | |
| 3 | PANIPAT TPS | 0.70 | 10.1 | 6.61 | 9.0 | 0.0 | 38.3 | 38.3 | 4 | | |
| 4 | RAJIV GANDHI TPS | 0.70 | 16.3 | 11.06 | 15.3 | 36.6 | 99.5 | 136.1 | 9 | | |
| 5 | YAMUNA NAGAR TPS | 0.71 | 9.8 | 5.60 | 8.8 | 38.8 | 40.7 | 79.6 | 9 | | |
| Punjab | | | | | | | | | | | |
| 6 | GH TPS (LEH.MOH.) | 0.67 | 1.1 | 8.13 | 8.1 | 180.6 | 18.6 | 199.2 | 25 | | |
| 7 | GOINDWAL SAHIB TPP | 0.71 | 0.0 | 5.05 | 5.1 | 2.2 | 0.0 | 2.2 | 0 | | Plant is lifting coal through road mode |
| 8 | RAJPURA TPP | 0.56 | 17.4 | 10.41 | 17.4 | 221.6 | 0.0 | 221.6 | 13 | | |
| 9 | ROPAR TPS | 0.69 | 0.7 | 7.61 | 7.6 | 257.5 | 1.1 | 258.6 | 34 | | |
| 10 | TALWANDI SABO TPP | 0.68 | 19.8 | 17.68 | 19.8 | 144.9 | 0.0 | 144.9 | 7 | | |
| Rajasthan | | | | | | | | | | | |
| 11 | CHHABRA-I PH-1 TPP | 0.65 | 6.3 | 4.29 | 6.3 | 13.4 | 0.0 | 13.4 | 2 | | Materialization against the ACQ is more than trigger level |
| 12 | KAWAI TPS | 0.58 | 16.7 | 10.14 | 16.7 | 62.0 | 91.0 | 153.0 | 9 | | Materialization against the ACQ is more than trigger level |
| 13 | KOTA TPS | 0.71 | 16.5 | 11.63 | 16.5 | 44.8 | 0.0 | 44.8 | 3 | | |
| 14 | SURATGARH TPS | 0.61 | 6.4 | 12.05 | 12.1 | 67.8 | 0.0 | 67.8 | 6 | | |
| Uttar Pradesh | | | | | | | | | | | |
| 15 | ANPARA C TPS | 0.64 | 14.0 | 10.09 | 12.9 | 40.0 | 0.0 | 40.0 | 3 | | Materialization against the ACQ is more than trigger level |
| 16 | ANPARA TPS | 0.65 | 38.0 | 22.72 | 37.0 | 514.9 | 0.0 | 514.9 | 14 | | |
| 17 | BARKHERA TPS | 0.80 | 0.0 | 0.96 | 1.0 | 22.5 | 0.0 | 22.5 | 23 | | Plant is requested to increase lifting through road mode |
| 18 | DADRI (NCTPP) | 0.67 | 11.4 | 16.15 | 16.1 | 222.6 | 77.4 | 300.0 | 19 | | |
| 19 | HARDUAGANJ TPS | 0.72 | 5.2 | 12.05 | 12.1 | 128.5 | 0.0 | 128.5 | 11 | | Materialization against the ACQ is more than trigger level |
| 20 | KHAMBARKHERA TPS | 0.80 | 0.0 | 0.95 | 1.0 | 23.8 | 0.0 | 23.8 | 25 | | Plant is requested to increase lifting through road mode |
| 21 | KUNDARKI TPS | 0.77 | 0.0 | 0.91 | 0.9 | 29.1 | 0.0 | 29.1 | 32 | | Plant is requested to increase lifting through road mode |
| 22 | LALITPUR TPS | 0.61 | 5.1 | 16.06 | 16.1 | 364.6 | 0.0 | 364.6 | 23 | | Materialization against the ACQ is more than trigger level |
| 23 | MAQSOODPUR TPS | 0.79 | 0.0 | 0.94 | 0.9 | 21.1 | 0.0 | 21.1 | 22 | | Plant is requested to increase lifting through road mode |
| 24 | MEJA STPP | 0.67 | 17.3 | 11.62 | 17.3 | 177.3 | 18.3 | 195.5 | 11 | | |
| 25 | OBRA TPS | 0.74 | 14.2 | 10.75 | 14.2 | 38.8 | 0.0 | 38.8 | 3 | | Materialization against the ACQ is more than trigger level |
| 26 | PARICHHHA TPS | 0.70 | 9.9 | 10.60 | 10.6 | 15.8 | 0.0 | 15.8 | 1 | | Materialization against the ACQ is more than trigger level |
| 27 | PRAYAGRAJ TPP | 0.60 | 23.6 | 15.69 | 23.6 | 49.1 | 0.0 | 49.1 | 2 | | |
| 28 | RIHAND STPS | 0.60 | 40.1 | 23.92 | 40.1 | 785.3 | 0.0 | 785.3 | 20 | | |
| 29 | ROSA TPP Ph-I | 0.63 | 12.0 | 10.02 | 12.0 | 52.4 | 0.0 | 52.4 | 4 | | Materialization against the ACQ is more than trigger level |
| 30 | SINGRAULI STPS | 0.65 | 29.9 | 17.29 | 29.9 | 401.8 | 0.0 | 401.8 | 13 | | |
| 31 | TANDA TPS | 0.69 | 0.0 | 15.98 | 16.0 | 280.4 | 102.8 | 383.2 | 24 | | |
| 32 | UNCHAHAAR TPS | 0.67 | 6.6 | 13.76 | 13.8 | 248.0 | 98.5 | 346.5 | 25 | | |
| 33 | UTRAULA TPS | 0.79 | 0.0 | 0.94 | 0.9 | 29.5 | 0.0 | 29.5 | 32 | | Plant is requested to increase lifting through road mode |
| Total of Northern Region | | | | | | | | | | 0 | |
| Western | | | | | | | | | | | |
| Chhatisgarh | | | | | | | | | | | |
| 34 | AKALTARA TPS | 0.65 | 20.1 | 15.38 | 20.1 | 216.9 | 0.0 | 216.9 | 11 | | Materialization against the ACQ is more than trigger level |

COAL INDIA LIMITED

MARKETING & SALES DIVISION

COAL STOCK POSITION OF POWER PLANTS HAVING COAL LINKAGE WITH COAL INDIA LIMITED & SCCL AS PER CEA REPORT

| Region/State | Name of Thermal Power Station | Specific Coal Consumption (Kcal/kg) | Consumption for last 07 days (Average)* | Requirement @ 55% PLF | Requirement for the day (In '000 Tonnes') (Higher of D and E) | Actual Stock (In 000 Te) | | | In Days | Status of Criticality as per "New methodology for monitoring of coal stock at coal based thermal power plants" dated 08.11.2017 Critical(*)/Supercritical(**) | Reasons for not considering the plant under critical/super critical category inspite of plant carrying low stock |
|----------------|-------------------------------|-------------------------------------|---|-----------------------|---|--------------------------|--------|-------|---------|---|--|
| | | | | | | Indigenous | Import | Total | | | |
| A | B | C | D | E | F | G | H | I | J=(I/F) | | |
| 35 | BALCO TPS | 0.74 | 5.4 | 5.83 | 5.8 | 36.4 | 0.0 | 36.4 | 6 | | |
| 36 | BANDAKHAR TPP | 0.70 | 0.1 | 2.78 | 2.8 | 102.5 | 0.0 | 102.5 | 37 | | |
| 37 | BARADARHA TPS | 0.75 | 9.0 | 11.88 | 11.9 | 156.9 | 0.0 | 156.9 | 13 | | |
| 38 | BHILAI TPS | 0.76 | 8.3 | 4.99 | 8.3 | 50.3 | 29.9 | 80.3 | 10 | | |
| 39 | BINKOTE TPP | 0.75 | 2.3 | 5.91 | 5.9 | 11.8 | 0.0 | 11.8 | 2 | | Materialization against the ACQ is more than trigger level |
| 40 | DSPM TPS | 0.72 | 7.4 | 4.74 | 7.4 | 36.9 | 0.0 | 36.9 | 5 | | |
| 41 | KORBA STPS | 0.66 | 40.9 | 22.82 | 40.9 | 448.4 | 0.0 | 448.4 | 11 | | |
| 42 | KORBA-WEST TPS | 0.77 | 20.8 | 13.55 | 20.8 | 102.4 | 0.0 | 102.4 | 5 | | |
| 43 | LARA TPP | 0.70 | 23.2 | 14.77 | 22.4 | 188.3 | 4.0 | 192.3 | 9 | | |
| 44 | NAWAPARA TPP | 0.79 | 8.5 | 6.28 | 8.5 | 48.8 | 0.0 | 48.8 | 6 | | |
| 45 | PATHADI TPP | 0.69 | 4.4 | 5.43 | 5.4 | 27.0 | 0.0 | 27.0 | 5 | | |
| 46 | SIPAT STPS | 0.67 | 33.0 | 26.38 | 33.0 | 487.9 | 48.5 | 536.4 | 16 | | |
| 47 | TAMNAR TPP | 0.82 | 19.5 | 25.98 | 25.0 | 517.4 | 22.9 | 540.3 | 22 | | |
| 48 | UCHPINDA TPP | 0.77 | 6.2 | 14.56 | 13.6 | 414.4 | 0.0 | 414.4 | 30 | | Materialization against the ACQ is more than trigger level |
| Gujarat | | | | | | | | | | | |
| 49 | GANDHI NAGAR TPS | 0.67 | 7.3 | 5.55 | 7.3 | 62.0 | 28.5 | 90.5 | 12 | | |
| 50 | SABARMATI (D-F STATIONS) | 0.57 | 3.3 | 2.70 | 3.3 | 12.6 | 80.1 | 92.7 | 10 | | Materialization against the ACQ is more than trigger level |
| 51 | UKAI TPS | 0.68 | 9.6 | 10.01 | 10.0 | 95.7 | 78.6 | 174.3 | 17 | | |
| 52 | WANAKBORI TPS | 0.68 | 25.7 | 20.45 | 22.1 | 133.6 | 70.3 | 203.9 | 9 | | |
| Madhya Pradesh | | | | | | | | | | | |
| 53 | AMARKANTAK EXT TPS | 0.65 | 3.3 | 1.81 | 3.3 | 81.9 | 0.0 | 81.9 | 25 | | |
| 54 | ANUPPUR TPP | 0.70 | 10.6 | 11.14 | 11.1 | 115.5 | 114.6 | 230.1 | 21 | | |
| 55 | BINA TPS | 0.72 | 3.3 | 4.77 | 4.8 | 25.4 | 0.0 | 25.4 | 5 | | Materialization against the ACQ is more than trigger level |
| 56 | GADARWARA TPP | 0.64 | 3.8 | 13.61 | 13.6 | 323.9 | 109.5 | 433.4 | 32 | | |
| 57 | KHARGONE STPP | 0.61 | 0.0 | 10.56 | 10.6 | 222.4 | 121.0 | 343.4 | 33 | | |
| 58 | SANJAY GANDHI TPS | 0.77 | 18.9 | 13.63 | 18.9 | 46.5 | 0.0 | 46.5 | 2 | | Non payment of dues |
| 59 | SATPURA TPS | 0.65 | 7.4 | 11.47 | 11.5 | 110.4 | 0.0 | 110.4 | 10 | | |
| 60 | SEIONI TPP | 0.62 | 7.0 | 4.91 | 7.0 | 51.7 | 0.0 | 51.7 | 7 | | Materialization against the ACQ is more than trigger level |
| 61 | SHREE SINGAJI TPP | 0.73 | 25.2 | 24.31 | 25.2 | 208.9 | 0.0 | 208.9 | 8 | | Non Payment of Dues |
| 62 | VINDHYACHAL STPS | 0.67 | 73.2 | 42.33 | 73.2 | 741.1 | 0.0 | 741.1 | 10 | | |
| Maharashtra | | | | | | | | | | | |
| 63 | AMRAVATI TPS | 0.65 | 15.4 | 11.60 | 15.4 | 41.0 | 0.0 | 41.0 | 3 | | Materialization against the ACQ is more than trigger level |
| 64 | BHUSAWAL TPS | 0.77 | 14.0 | 12.31 | 14.0 | 129.7 | 106.1 | 235.8 | 17 | | Non payment of dues |
| 65 | BUTIBORI TPP | 0.67 | 0.0 | 5.31 | 5.3 | 59.7 | 0.0 | 59.7 | 11 | | |
| 66 | CHANDRAPUR(MAHARASHTRA) STPS | 0.79 | 30.3 | 30.35 | 30.3 | 154.3 | 277.0 | 431.3 | 14 | | |
| 67 | DAHANU TPS | 0.60 | 5.9 | 3.96 | 5.9 | 13.0 | 2.5 | 15.5 | 3 | | Materialization against the ACQ is more than trigger level |
| 68 | DHARIWAL TPP | 0.68 | 8.1 | 5.40 | 8.1 | 19.9 | 29.3 | 49.1 | 6 | | Materialization against the ACQ is more than trigger level |
| 69 | GMR WARORA TPS | 0.67 | 8.3 | 5.28 | 8.3 | 35.8 | 0.0 | 35.8 | 4 | | |
| 70 | KHAPARKHEDA TPS | 0.87 | 17.6 | 15.37 | 15.9 | 76.8 | 5.5 | 82.3 | 5 | | |
| 71 | KORADI TPS | 0.73 | 24.1 | 20.96 | 23.2 | 132.1 | 38.4 | 170.5 | 7 | | |
| 72 | MAUDA TPS | 0.71 | 14.0 | 21.75 | 21.7 | 359.6 | 71.4 | 431.0 | 20 | | |
| 73 | NASIK TPS | 0.83 | 5.5 | 6.93 | 6.9 | 60.7 | 19.8 | 80.6 | 12 | | |
| 74 | PARAS TPS | 0.76 | 3.8 | 5.01 | 5.0 | 143.4 | 0.0 | 143.4 | 29 | | |
| 75 | PARLI TPS | 0.67 | 6.6 | 6.60 | 6.6 | 117.9 | 0.0 | 117.9 | 18 | | |
| 76 | SOLAPUR STPS | 0.62 | 0.0 | 10.88 | 10.9 | 184.4 | 131.7 | 316.0 | 29 | | |

COAL INDIA LIMITED

MARKETING & SALES DIVISION

COAL STOCK POSITION OF POWER PLANTS HAVING COAL LINKAGE WITH COAL INDIA LIMITED & SCCL AS PER CEA REPORT

| Region/State | Name of Thermal Power Station | Specific Coal Consumption (Kcal/kg) | Consumption for last 07 days (Average)* | Requirement @ 55% PLF | Requirement for the day (In '000 Tonnes') (Higher of D and E) | Actual Stock (In 000 Te) | | | In Days | Status of Criticality as per "New methodology for monitoring of coal stock at coal based thermal power plants" dated 08.11.2017 Critical(*)/Supercritical(**) | Reasons for not considering the plant under critical/super critical category inspite of plant carrying low stock |
|--------------------------|-------------------------------|-------------------------------------|---|-----------------------|---|--------------------------|--------|-------|---------|---|--|
| | | | | | | Indigenous | Import | Total | | | |
| A | B | C | D | E | F | G | H | I | J=(I/F) | | |
| 77 | TIRORA TPS | 0.66 | 35.6 | 28.54 | 35.6 | 198.7 | 0.0 | 198.7 | 6 | | Materialization against the ACQ is more than trigger level |
| 78 | WARDHA WARORA TPP | 0.65 | 4.0 | 4.60 | 4.6 | 19.8 | 3.1 | 22.9 | 5 | | |
| Total of Western Region | | | | | | | | | | 0 | |
| Southern | | | | | | | | | | | |
| Andhra Pradesh | | | | | | | | | | | |
| 79 | DAMODARAM SANJEEVAIAH TPS | 0.64 | 3.5 | 13.52 | 13.5 | 17.0 | 0.0 | 17.0 | 1 | | |
| 80 | Dr. N.TATA RAO TPS | 0.80 | 25.8 | 18.48 | 25.8 | 68.0 | 0.0 | 68.0 | 3 | | Materialization against the ACQ is more than trigger level |
| 81 | PAINAMPURAM TPP | 0.61 | 14.2 | 10.55 | 13.3 | 101.5 | 310.3 | 411.8 | 31 | | |
| 82 | RAYALASEEMA TPS | 0.75 | 22.5 | 16.34 | 21.0 | 25.2 | 0.0 | 25.2 | 1 | | Materialization against the ACQ is more than trigger level |
| 83 | SIMHADRI | 0.77 | 20.2 | 20.40 | 19.4 | 699.2 | 5.0 | 704.3 | 36 | | |
| 84 | SGPL TPP | 0.55 | 13.1 | 9.56 | 12.6 | 103.8 | 345.0 | 448.8 | 36 | | Materialization against the ACQ is more than trigger level |
| 85 | VIZAG TPP | 0.75 | 13.0 | 10.23 | 12.7 | 124.3 | 0.0 | 124.3 | 10 | | Less Supply of rakes from Railways |
| Karnataka | | | | | | | | | | | |
| 86 | BELLARY TPS | 0.66 | 9.6 | 14.82 | 13.8 | 162.8 | 2.3 | 165.1 | 12 | | |
| 87 | KUDGI STPP | 0.59 | 3.6 | 18.81 | 17.8 | 480.2 | 145.9 | 626.1 | 35 | | |
| 88 | RAICHUR TPS | 0.71 | 9.6 | 16.05 | 15.1 | 155.9 | 0.0 | 155.9 | 10 | | |
| 89 | YERMARUS TPP | 0.61 | 7.3 | 12.91 | 11.9 | 75.1 | 0.0 | 75.1 | 6 | | |
| Tamil Nadu | | | | | | | | | | | |
| 90 | METTUR TPS | 0.81 | 14.4 | 8.97 | 13.5 | 33.3 | 0.0 | 33.3 | 2 | | |
| 91 | METTUR TPS - II | 0.78 | 8.9 | 6.20 | 8.9 | 51.5 | 52.1 | 103.5 | 12 | | |
| 92 | NORTH CHENNAI TPS | 0.96 | 14.8 | 23.11 | 22.1 | 144.5 | 136.2 | 280.8 | 13 | | |
| 93 | TUTICORIN TPS | 0.93 | 17.2 | 12.84 | 16.5 | 9.5 | 0.0 | 9.5 | 1 | | |
| 94 | VALLUR TPP | 0.75 | 19.9 | 14.94 | 17.1 | 300.5 | 0.0 | 300.5 | 18 | | |
| Telangana | | | | | | | | | | | |
| 95 | BHADRADRI TPP | 0.60 | 14.6 | 8.55 | 14.6 | 223.3 | 0.0 | 223.3 | 15 | | |
| 96 | KAKATIYA TPS | 0.58 | 13.4 | 8.38 | 13.4 | 199.2 | 0.0 | 199.2 | 15 | | |
| 97 | KOTHAGUDEM TPS (NEW) | 0.66 | 11.7 | 8.72 | 11.7 | 217.8 | 0.0 | 217.8 | 19 | | |
| 98 | KOTHAGUDEM TPS (STAGE-7) | 0.50 | 5.6 | 5.24 | 5.6 | 137.8 | 0.0 | 137.8 | 25 | | |
| 99 | RAMAGUNDEM STPS | 0.62 | 25.6 | 21.26 | 25.6 | 273.5 | 69.8 | 343.2 | 13 | | |
| 100 | RAMAGUNDEM-B TPS | 0.75 | 0.0 | 0.62 | 0.6 | 15.9 | 0.0 | 15.9 | 26 | | |
| 101 | SINGARENI TPP | 0.58 | 14.5 | 9.16 | 14.5 | 196.6 | 0.0 | 196.6 | 14 | | |
| Total of Southern Region | | | | | | | | | | 0 | |
| Eastern | | | | | | | | | | | |
| Bihar | | | | | | | | | | | |
| 102 | BARAUNI TPS | 0.63 | 6.3 | 5.93 | 6.3 | 53.2 | 0.0 | 53.2 | 8 | | |
| 103 | BARH STPS | 0.66 | 4.7 | 17.14 | 17.1 | 292.8 | 0.0 | 292.8 | 17 | | |
| 104 | KAHALGAON TPS | 0.75 | 14.1 | 23.08 | 22.1 | 403.0 | 10.6 | 413.6 | 19 | | |
| #REF! | MUZAFFARPUR TPS | 0.73 | 6.1 | 3.73 | 6.1 | 39.3 | 0.0 | 39.3 | 6 | | |
| #REF! | NABINAGAR STPP | 0.61 | 25.8 | 15.90 | 25.8 | 210.0 | 12.2 | 222.3 | 9 | | |
| #REF! | NABINAGAR TPP | 0.69 | 13.9 | 9.16 | 13.9 | 122.0 | 20.3 | 142.3 | 10 | | |
| Jharkhand | | | | | | | | | | | |
| 108 | BOKARO TPS 'A' EXP | 0.58 | 5.9 | 3.81 | 5.9 | 34.3 | 9.7 | 44.0 | 7 | | |
| 109 | CHANDRAPURA(DVC) TPS | 0.62 | 6.2 | 4.07 | 6.2 | 25.6 | 40.1 | 65.7 | 11 | | |
| 110 | JOJBERA TPS | 0.67 | 2.8 | 2.13 | 2.8 | 46.9 | 0.0 | 46.9 | 17 | | |
| 111 | KODARMA TPP | 0.62 | 12.8 | 8.19 | 12.8 | 67.2 | 32.0 | 99.2 | 8 | | |
| 112 | MAHADEV PRASAD STPP | 0.68 | 3.4 | 4.85 | 4.8 | 56.7 | 0.0 | 56.7 | 12 | | |
| 113 | MAITHON RB TPP | 0.61 | 13.0 | 8.47 | 13.0 | 260.8 | 0.0 | 260.8 | 20 | | |
| 114 | TENUGHAT TPS | 0.72 | 3.8 | 4.00 | 4.0 | 33.7 | 0.0 | 33.7 | 8 | | Materialization against the ACQ is more than trigger level |
| Odisha | | | | | | | | | | | |
| 115 | DARLIPALI STPS | 0.70 | 27.7 | 14.78 | 27.7 | 88.9 | 0.0 | 88.9 | 3 | | |
| 116 | DERANG TPP | 0.68 | 13.3 | 10.85 | 13.3 | 820.4 | 0.0 | 820.4 | 62 | | |

