

COAL INDIA LIMITED

MARKETING & SALES DIVISION

COAL STOCK POSITION OF POWER PLANTS HAVING COAL LINKAGE WITH COAL INDIA LIMITED & SCCL AS PER CEA REPORT

| Region/State | Name of Thermal Power Station | Specific Coal Consumption (Kcal/kg) | Consumption for last 07 days (Average)* | Requirement @ 55% PLF | Requirement for the day (In '000 Tonnes') (Higher of D and E) | Actual Stock (In 000 Te) | | | In Days | Status of Criticality as per "New methodology for monitoring of coal stock at coal based thermal power plants" dated 08.11.2017 Critical(*)/Supercritical(**) | Reasons for not considering the plant under critical/super critical category inspite of plant carrying low stock |
|--------------------------|-------------------------------|-------------------------------------|---|-----------------------|---|--------------------------|--------|-------|---------|---|--|
| | | | | | | Indigenous | Import | Total | | | |
| A | B | C | D | E | F | G | H | I | J=(I/F) | | |
| Haryana | | | | | | | | | | | |
| 1 | INDIRA GANDHI STPP | 0.66 | 10.0 | 13.11 | 13.1 | 391.5 | 57.2 | 448.6 | 34 | | |
| 2 | MAHATMA GANDHI TPS | 0.61 | 16.6 | 10.59 | 16.6 | 220.9 | 73.6 | 294.4 | 18 | | |
| 3 | PANIPAT TPS | 0.70 | 10.9 | 6.61 | 10.9 | 39.4 | 53.3 | 92.8 | 8 | | |
| 4 | RAJIV GANDHI TPS | 0.70 | 12.3 | 11.06 | 12.3 | 36.7 | 108.3 | 145.0 | 12 | | |
| 5 | YAMUNA NAGAR TPS | 0.71 | 4.1 | 5.60 | 5.6 | 91.0 | 51.3 | 142.3 | 25 | | |
| Punjab | | | | | | | | | | | |
| 6 | GH TPS (LEH.MOH.) | 0.67 | 7.9 | 8.13 | 8.1 | 125.7 | 2.0 | 127.8 | 16 | | |
| 7 | GOINDWAL SAHIB TPP | 0.71 | 6.5 | 5.05 | 6.5 | 23.2 | 0.0 | 23.2 | 4 | | Plant is lifting coal through road mode |
| 8 | RAJPURA TPP | 0.56 | 9.0 | 10.41 | 10.4 | 338.5 | 0.0 | 338.5 | 33 | | |
| 9 | ROPAR TPS | 0.69 | 6.6 | 7.61 | 7.6 | 179.3 | 0.0 | 179.3 | 24 | | |
| 10 | TALWANDI SABO TPP | 0.68 | 26.2 | 17.68 | 26.2 | 89.9 | 0.0 | 89.9 | 3 | | |
| Rajasthan | | | | | | | | | | | |
| 11 | CHHABRA-I PH-1 TPP | 0.65 | 6.3 | 4.29 | 6.3 | 1.5 | 0.0 | 1.5 | 0 | | Materialization against the ACQ is more than trigger level |
| 12 | KAWAI TPS | 0.58 | 15.5 | 10.14 | 15.5 | 34.7 | 190.1 | 224.9 | 14 | | Materialization against the ACQ is more than trigger level |
| 13 | KOTA TPS | 0.71 | 15.5 | 11.63 | 15.5 | 55.7 | 0.0 | 55.7 | 4 | | |
| 14 | SURATGARH TPS | 0.61 | 12.4 | 12.05 | 12.4 | 96.2 | 0.0 | 96.2 | 8 | | |
| Uttar Pradesh | | | | | | | | | | | |
| 15 | ANPARA C TPS | 0.64 | 7.7 | 10.09 | 10.1 | 55.2 | 0.0 | 55.2 | 5 | | Materialization against the ACQ is more than trigger level |
| 16 | ANPARA TPS | 0.65 | 31.3 | 22.72 | 31.3 | 714.0 | 0.0 | 714.0 | 23 | | |
| 17 | BARKHERA TPS | 0.80 | 0.0 | 0.96 | 1.0 | 36.5 | 0.0 | 36.5 | 38 | | Plant is requested to increase lifting through road mode |
| 18 | DADRI (NCTPP) | 0.67 | 15.4 | 16.15 | 16.1 | 264.3 | 65.1 | 329.3 | 20 | | |
| 19 | HARDUAGANJ TPS | 0.72 | 7.2 | 12.05 | 12.1 | 279.5 | 0.0 | 279.5 | 23 | | Materialization against the ACQ is more than trigger level |
| 20 | KHAMBARKHERA TPS | 0.80 | 0.0 | 0.95 | 1.0 | 31.3 | 0.0 | 31.3 | 33 | | Plant is requested to increase lifting through road mode |
| 21 | KUNDARKI TPS | 0.77 | 0.0 | 0.91 | 0.9 | 44.9 | 0.0 | 44.9 | 49 | | Plant is requested to increase lifting through road mode |
| 22 | LALITPUR TPS | 0.61 | 17.9 | 16.06 | 17.9 | 434.3 | 0.0 | 434.3 | 24 | | Materialization against the ACQ is more than trigger level |
| 23 | MAQSOODPUR TPS | 0.79 | 0.0 | 0.94 | 0.9 | 36.8 | 0.0 | 36.8 | 39 | | Plant is requested to increase lifting through road mode |
| 24 | MEJA STPP | 0.67 | 16.2 | 11.62 | 16.2 | 119.8 | 21.1 | 140.9 | 9 | | |
| 25 | OBRA TPS | 0.74 | 13.0 | 9.83 | 13.0 | 70.5 | 0.0 | 70.5 | 5 | | Materialization against the ACQ is more than trigger level |
| 26 | PARICHAHA TPS | 0.70 | 8.8 | 10.60 | 10.6 | 132.5 | 0.0 | 132.5 | 12 | | Materialization against the ACQ is more than trigger level |
| 27 | PRAYAGRAJ TPP | 0.60 | 21.7 | 15.69 | 21.7 | 54.1 | 0.0 | 54.1 | 2 | | |
| 28 | RIHAND STPS | 0.60 | 34.2 | 23.92 | 34.2 | 961.7 | 0.0 | 961.7 | 28 | | |
| 29 | ROSA TPP Ph-I | 0.63 | 16.3 | 10.02 | 16.3 | 69.4 | 0.0 | 69.4 | 4 | | Materialization against the ACQ is more than trigger level |
| 30 | SINGRAULI STPS | 0.65 | 26.6 | 17.29 | 26.6 | 406.9 | 0.0 | 406.9 | 15 | | |
| 31 | TANDA TPS | 0.69 | 15.0 | 15.98 | 16.0 | 304.7 | 89.0 | 393.7 | 25 | | |
| 32 | UNCHAHAHAR TPS | 0.67 | 5.2 | 13.76 | 13.8 | 480.9 | 92.3 | 573.3 | 42 | | |
| 33 | UTRAULA TPS | 0.79 | 0.0 | 0.94 | 0.9 | 51.0 | 0.0 | 51.0 | 55 | | Plant is requested to increase lifting through road mode |
| Total of Northern Region | | | | | | | | | | 0 | |
| Western Chhatisgarh | | | | | | | | | | | |
| 34 | AKALTARA TPS | 0.65 | 21.4 | 15.38 | 21.4 | 102.4 | 0.0 | 102.4 | 5 | | Materialization against the ACQ is more than trigger level |

COAL INDIA LIMITED

MARKETING & SALES DIVISION

COAL STOCK POSITION OF POWER PLANTS HAVING COAL LINKAGE WITH COAL INDIA LIMITED & SCCL AS PER CEA REPORT

| Region/State | Name of Thermal Power Station | Specific Coal Consumption (Kcal/kg) | Consumption for last 07 days (Average)* | Requirement @ 55% PLF | Requirement for the day (In '000 Tonnes') (Higher of D and E) | Actual Stock (In 000 Te) | | | In Days | Status of Criticality as per "New methodology for monitoring of coal stock at coal based thermal power plants" dated 08.11.2017 Critical(*)/Supercritical(**) | Reasons for not considering the plant under critical/super critical category inspite of plant carrying low stock |
|----------------|-------------------------------|-------------------------------------|---|-----------------------|---|--------------------------|--------|-------|---------|---|--|
| | | | | | | Indigenous | Import | Total | | | |
| A | B | C | D | E | F | G | H | I | J=(I/F) | | |
| 35 | BALCO TPS | 0.74 | 0.0 | 5.83 | 5.8 | 186.8 | 0.0 | 186.8 | 32 | | |
| 36 | BANDAKHAR TPP | 0.70 | 4.8 | 2.78 | 4.8 | 55.0 | 0.0 | 55.0 | 11 | | |
| 37 | BARADARHA TPS | 0.75 | 12.6 | 11.88 | 12.6 | 147.9 | 0.0 | 147.9 | 12 | | |
| 38 | BHILAI TPS | 0.76 | 4.1 | 4.99 | 5.0 | 111.3 | 24.9 | 136.1 | 27 | | |
| 39 | BINJKOTE TPP | 0.75 | 4.8 | 5.91 | 5.9 | 12.4 | 0.0 | 12.4 | 2 | | Materialization against the ACQ is more than trigger level |
| 40 | DSPM TPS | 0.72 | 8.3 | 4.74 | 8.3 | 136.3 | 0.0 | 136.3 | 16 | | |
| 41 | KORBA STPS | 0.66 | 45.4 | 22.82 | 45.4 | 353.8 | 0.0 | 353.8 | 8 | | |
| 42 | KORBA-WEST TPS | 0.77 | 20.3 | 13.55 | 20.3 | 180.5 | 0.0 | 180.5 | 9 | | |
| 43 | LARA TPP | 0.70 | 22.8 | 14.77 | 22.8 | 312.2 | 32.7 | 344.9 | 15 | | |
| 44 | NAWAPARA TPP | 0.79 | 8.3 | 6.28 | 8.3 | 56.9 | 0.0 | 56.9 | 7 | | |
| 45 | PATHADI TPP | 0.69 | 6.1 | 5.43 | 6.1 | 136.9 | 0.9 | 137.8 | 23 | | |
| 46 | SIPAT STPS | 0.67 | 43.0 | 26.38 | 43.0 | 618.0 | 41.6 | 659.6 | 15 | | |
| 47 | TAMNAR TPP | 0.82 | 28.4 | 25.98 | 28.4 | 431.7 | 59.7 | 491.4 | 17 | | |
| 48 | UCHPINDA TPP | 0.77 | 12.8 | 14.56 | 14.6 | 518.7 | 0.0 | 518.7 | 36 | | Materialization against the ACQ is more than trigger level |
| Gujarat | | | | | | | | | | | |
| 49 | GANDHI NAGAR TPS | 0.67 | 8.0 | 5.55 | 8.0 | 32.6 | 28.5 | 61.1 | 8 | | |
| 50 | SABARMATI (D-F STATIONS) | 0.57 | 3.3 | 2.70 | 3.3 | 24.7 | 75.0 | 99.7 | 12 | | Materialization against the ACQ is more than trigger level |
| 51 | UKAI TPS | 0.68 | 9.4 | 10.01 | 10.0 | 119.6 | 78.6 | 198.2 | 20 | | |
| 52 | WANAKBORI TPS | 0.68 | 17.6 | 20.45 | 20.4 | 208.7 | 78.3 | 286.9 | 14 | | |
| Madhya Pradesh | | | | | | | | | | | |
| 53 | AMARKANTAK EXT TPS | 0.65 | 3.2 | 1.81 | 3.2 | 53.3 | 0.0 | 53.3 | 17 | | |
| 54 | ANUPPUR TPP | 0.70 | 15.0 | 11.14 | 15.0 | 145.3 | 97.6 | 242.9 | 16 | | |
| 55 | BINA TPS | 0.72 | 3.5 | 4.77 | 4.8 | 75.8 | 0.0 | 75.8 | 16 | | Materialization against the ACQ is more than trigger level |
| 56 | GADARWARA TPP | 0.64 | 20.6 | 13.61 | 20.6 | 106.8 | 107.1 | 213.9 | 10 | | |
| 57 | KHARGONE STPP | 0.61 | 14.3 | 10.56 | 14.3 | 69.6 | 75.3 | 144.9 | 10 | | |
| 58 | SANJAY GANDHI TPS | 0.77 | 18.0 | 13.63 | 18.0 | 79.2 | 0.0 | 79.2 | 4 | | Non payment of dues |
| 59 | SATPURA TPS | 0.65 | 7.5 | 11.47 | 11.5 | 81.1 | 0.0 | 81.1 | 7 | | |
| 60 | SEIONI TPP | 0.62 | 7.3 | 4.91 | 7.3 | 38.8 | 0.0 | 38.8 | 5 | | Materialization against the ACQ is more than trigger level |
| 61 | SHREE SINGAJI TPP | 0.73 | 28.5 | 24.31 | 28.5 | 125.6 | 0.0 | 125.6 | 4 | | Non Payment of Dues |
| 62 | VINDHYACHAL STPS | 0.67 | 65.7 | 42.33 | 65.7 | 904.8 | 0.0 | 904.8 | 14 | | |
| Maharashtra | | | | | | | | | | | |
| 63 | AMRAVATI TPS | 0.65 | 20.0 | 11.60 | 20.0 | 29.0 | 0.0 | 29.0 | 1 | | Materialization against the ACQ is more than trigger level |
| 64 | BHUSAWAL TPS | 0.77 | 14.8 | 12.31 | 14.8 | 99.5 | 129.7 | 229.2 | 16 | | Non payment of dues |
| 65 | BUTIBORI TPP | 0.67 | 0.0 | 5.31 | 5.3 | 59.7 | 0.0 | 59.7 | 11 | | |
| 66 | CHANDRAPUR(MAHARASHTRA) STPS | 0.79 | 30.4 | 30.35 | 30.4 | 555.6 | 212.4 | 768.0 | 25 | | |
| 67 | DAHANU TPS | 0.60 | 6.1 | 3.96 | 6.1 | 19.0 | 0.0 | 19.0 | 3 | | Materialization against the ACQ is more than trigger level |
| 68 | DHARIWAL TPP | 0.68 | 7.2 | 5.40 | 7.2 | 45.2 | 6.1 | 51.3 | 7 | | Materialization against the ACQ is more than trigger level |
| 69 | GMR WARORA TPS | 0.67 | 8.4 | 5.28 | 8.4 | 22.0 | 0.0 | 22.0 | 3 | | |
| 70 | KHAPARKHEDA TPS | 0.87 | 18.0 | 15.37 | 18.0 | 187.4 | 14.4 | 201.8 | 11 | | |
| 71 | KORADI TPS | 0.73 | 30.2 | 20.96 | 30.2 | 115.8 | 50.4 | 166.2 | 5 | | |
| 72 | MAUDA TPS | 0.71 | 24.0 | 21.75 | 24.0 | 252.4 | 78.6 | 331.1 | 14 | | |
| 73 | NASIK TPS | 0.83 | 6.9 | 6.93 | 6.9 | 86.1 | 20.8 | 107.0 | 15 | | |
| 74 | PARAS TPS | 0.76 | 7.1 | 5.01 | 7.1 | 90.6 | 0.0 | 90.6 | 13 | | |
| 75 | PARLI TPS | 0.67 | 7.9 | 6.60 | 7.9 | 135.9 | 0.0 | 135.9 | 17 | | |
| 76 | SOLAPUR STPS | 0.62 | 17.7 | 10.88 | 17.7 | 146.3 | 107.0 | 253.3 | 14 | | |
| 77 | TIRORA TPS | 0.66 | 44.2 | 28.54 | 44.2 | 204.2 | 0.0 | 204.2 | 5 | | Materialization against the ACQ is more than trigger level |

COAL INDIA LIMITED

MARKETING & SALES DIVISION

COAL STOCK POSITION OF POWER PLANTS HAVING COAL LINKAGE WITH COAL INDIA LIMITED & SCCL AS PER CEA REPORT

| Region/State | Name of Thermal Power Station | Specific Coal Consumption (Kcal/kg) | Consumption for last 07 days (Average)* | Requirement @ 55% PLF | Requirement for the day (In '000 Tonnes') (Higher of D and E) | Actual Stock (In 000 Te) | | | In Days | Status of Criticality as per "New methodology for monitoring of coal stock at coal based thermal power plants" dated 08.11.2017 Critical(*)/Supercritical(**) | Reasons for not considering the plant under critical/super critical category inspite of plant carrying low stock |
|--------------------------|-------------------------------|-------------------------------------|---|-----------------------|---|--------------------------|--------|-------|---------|--|--|
| | | | | | | Indigenous | Import | Total | | | |
| A | B | C | D | E | F | G | H | I | J=(I/F) | | |
| 78 | WARDHA WARORA TPP | 0.65 | 5.9 | 4.60 | 5.9 | 10.8 | 0.0 | 10.8 | 2 | | |
| Total of Western Region | | | | | | | | | | | 0 |
| Southern | | | | | | | | | | | |
| Andhra Pradesh | | | | | | | | | | | |
| 79 | DAMODARAM SANJEEVAIAH TPS | 0.64 | 13.3 | 13.52 | 13.5 | 113.9 | 0.0 | 113.9 | 8 | | |
| 80 | Dr. N.TATA RAO TPS | 0.80 | 26.3 | 18.48 | 26.3 | 40.6 | 0.0 | 40.6 | 2 | | Materialization against the ACQ is more than trigger level |
| 81 | PAINAMPURAM TPP | 0.61 | 15.1 | 10.55 | 15.1 | 183.5 | 232.3 | 415.9 | 28 | | |
| 82 | RAYALASEEMA TPS | 0.75 | 18.7 | 16.34 | 18.7 | 58.2 | 0.0 | 58.2 | 3 | | Materialization against the ACQ is more than trigger level |
| 83 | SIMHADRI | 0.77 | 24.5 | 20.40 | 24.5 | 659.7 | 22.6 | 682.3 | 28 | | |
| 84 | SGPL TPP | 0.55 | 12.4 | 9.56 | 12.4 | 44.9 | 146.2 | 191.0 | 15 | | Materialization against the ACQ is more than trigger level |
| 85 | VIZAG TPP | 0.75 | 9.5 | 10.23 | 10.2 | 58.4 | 0.0 | 58.4 | 6 | | Less Supply of rakes from Railways |
| Karnataka | | | | | | | | | | | |
| 86 | BELLARY TPS | 0.66 | 17.3 | 14.82 | 17.3 | 56.2 | 0.0 | 56.2 | 3 | | |
| 87 | KUDGI STPP | 0.59 | 17.4 | 18.81 | 18.8 | 297.0 | 121.4 | 418.4 | 22 | | |
| 88 | RAICHUR TPS | 0.71 | 16.8 | 16.05 | 16.8 | 226.6 | 4.0 | 230.6 | 14 | | |
| 89 | YERMARUS TPP | 0.61 | 7.9 | 12.91 | 12.9 | 177.1 | 0.0 | 177.1 | 14 | | |
| Tamil Nadu | | | | | | | | | | | |
| 90 | METTUR TPS | 0.81 | 10.2 | 8.97 | 10.2 | 71.0 | 0.0 | 71.0 | 7 | | |
| 91 | METTUR TPS - II | 0.78 | 8.5 | 6.20 | 8.5 | 40.9 | 14.0 | 54.9 | 6 | | |
| 92 | NORTH CHENNAI TPS | 0.96 | 20.1 | 23.11 | 23.1 | 202.6 | 110.6 | 313.2 | 14 | | |
| 93 | TUTICORIN TPS | 0.93 | 16.0 | 12.84 | 16.0 | 5.6 | 0.0 | 5.6 | 0 | | |
| 94 | VALLUR TPP | 0.75 | 23.8 | 14.94 | 23.8 | 255.3 | 0.0 | 255.3 | 11 | | |
| Telangana | | | | | | | | | | | |
| 95 | BHADRADRI TPP | 0.60 | 11.9 | 8.55 | 11.9 | 268.7 | 0.0 | 268.7 | 23 | | |
| 96 | KAKATIYA TPS | 0.58 | 14.1 | 8.38 | 14.1 | 328.4 | 0.0 | 328.4 | 23 | | |
| 97 | KOTHAGUDEM TPS (NEW) | 0.66 | 13.3 | 8.72 | 13.3 | 200.9 | 0.0 | 200.9 | 15 | | |
| 98 | KOTHAGUDEM TPS (STAGE-7) | 0.50 | 8.7 | 5.24 | 8.7 | 146.9 | 0.0 | 146.9 | 17 | | |
| 99 | RAMAGUNDEM STPS | 0.62 | 27.0 | 21.26 | 27.0 | 497.4 | 28.8 | 526.2 | 19 | | |
| 100 | RAMAGUNDEM-B TPS | 0.75 | 0.0 | 0.62 | 0.6 | 11.9 | 0.0 | 11.9 | 19 | | |
| 101 | SINGARENI TPP | 0.58 | 14.5 | 9.16 | 14.5 | 213.9 | 0.0 | 213.9 | 15 | | |
| Total of Southern Region | | | | | | | | | | | 0 |
| Eastern | | | | | | | | | | | |
| Bihar | | | | | | | | | | | |
| 102 | BARAUNI TPS | 0.63 | 7.2 | 5.93 | 7.2 | 75.6 | 0.0 | 75.6 | 10 | | |
| 103 | BARH STPS | 0.66 | 24.9 | 17.14 | 24.9 | 429.1 | 0.0 | 429.1 | 17 | | |
| 104 | KAHALGAON TPS | 0.75 | 29.1 | 23.08 | 29.1 | 235.1 | 17.7 | 252.8 | 9 | | |
| #REF! | MUZAFFARPUR TPS | 0.73 | 5.8 | 3.73 | 5.8 | 65.3 | 0.0 | 65.3 | 11 | | |
| #REF! | NABINAGAR STPP | 0.61 | 17.3 | 15.90 | 17.3 | 356.1 | 66.3 | 422.4 | 24 | | |
| #REF! | NABINAGAR TPP | 0.69 | 14.4 | 9.16 | 14.4 | 140.0 | 6.2 | 146.2 | 10 | | |
| Jharkhand | | | | | | | | | | | |
| 108 | BOKARO TPS 'A' EXP | 0.58 | 6.7 | 3.81 | 6.7 | 87.5 | 3.1 | 90.6 | 13 | | |
| 109 | CHANDRAPURA(DVC) TPS | 0.62 | 7.4 | 4.07 | 7.4 | 46.7 | 39.7 | 86.4 | 12 | | |
| 110 | JOJOBERA TPS | 0.67 | 3.0 | 2.13 | 3.0 | 60.9 | 0.0 | 60.9 | 20 | | |
| 111 | KODARMA TPP | 0.62 | 13.5 | 8.19 | 13.5 | 60.9 | 42.5 | 103.4 | 8 | | |
| 112 | MAHADEV PRASAD STPP | 0.68 | 4.8 | 4.85 | 4.8 | 78.2 | 0.0 | 78.2 | 16 | | |
| 113 | MAITHON RB TPP | 0.61 | 13.6 | 8.47 | 13.6 | 272.1 | 0.0 | 272.1 | 20 | | |
| 114 | TENUGHAT TPS | 0.72 | 5.4 | 4.00 | 5.4 | 28.0 | 0.0 | 28.0 | 5 | | Materialization against the ACQ is more than trigger level |
| Odisha | | | | | | | | | | | |
| 115 | DARLIPALI STPS | 0.70 | 27.4 | 14.78 | 27.4 | 256.5 | 0.0 | 256.5 | 9 | | |
| 116 | DERANG TPP | 0.68 | 16.7 | 10.85 | 16.7 | 909.7 | 0.0 | 909.7 | 55 | | |
| 117 | IB VALLEY TPS | 0.79 | 25.8 | 18.05 | 25.8 | 262.1 | 0.0 | 262.1 | 10 | | |
| 118 | KAMALANGA TPS | 0.72 | 10.8 | 10.05 | 10.8 | 46.5 | 3.7 | 50.2 | 5 | | |

