

COAL INDIA LIMITED

MARKETING & SALES DIVISION

COAL STOCK POSITION OF POWER PLANTS HAVING COAL LINKAGE WITH COAL INDIA LIMITED & SCCL AS PER CEA REPORT

Region/State	Name of Thermal Power Station		Specific Coal Consumption (Kcal/kg)	Consumption for last 07 days (Average)*	Requirement @ 55% PLF	Requirement for the day (In '000 Tonnes') (Higher of D and E)	Actual Stock			Status of Criticality as per "New methodology for monitoring of coal stock at coal based thermal power plants" dated 08.11.2017 Critical(*)/Supercritical(**)	Reasons for not considering the plant under critical/super critical category inspite of plant carrying low stock	
							In '000 Tonnes'					In Days J=(U/F)
							Indigenous	Import	Total			
A	B		C	D	E	F	G	H	I	J=(U/F)		
Haryana												
1	INDIRA GANDHI STPP	JV	0.67	12.6	13.19	13.2	295.1	0.0	295.1	22		
2	MAHATMA GANDHI TPS	P	0.61	16.7	10.63	16.7	59.9	0.0	59.9	4		
3	PANIPAT TPS	S	0.71	7.1	6.68	7.1	113.6	0.0	113.6	16		
4	RAJIV GANDHI TPS	S	0.73	6.8	11.64	11.6	367.6	0.0	367.6	32		
5	YAMUNA NAGAR TPS	S	0.72	3.2	5.73	5.7	248.1	0.0	248.1	43		
Punjab												
6	GH TPS (LEH.MOH.)	S	0.68	1.6	8.28	8.3	236.6	0.0	236.6	29		
7	GOINDWAL SAHIB TPP	P	0.71	1.5	5.04	5.0	14.8	0.0	14.8	3		Materialization against the ACQ is more than trigger level
8	RAJPURA TPP	P	0.55	9.2	10.14	10.1	273.3	0.0	273.3	27		
9	ROPAR TPS	S	0.68	1.5	7.51	7.5	179.9	0.0	179.9	24		
10	TALWANDI SABO TPP	P	0.66	19.5	17.29	19.5	74.4	0.0	74.4	4		Materialization against the ACQ is more than trigger level
Rajasthan												
11	CHHABRA-I PH-1 TPP	S	0.50	6.6	3.31	6.6	4.2	0.0	4.2	1		Materialization against the ACQ is more than trigger level
12	KAWAI TPS	P	0.60	15.4	10.39	15.4	88.3	0.0	88.3	6		Materialization against the ACQ is more than trigger level
13	KOTA TPS	S	0.71	18.7	11.59	18.7	115.6	0.0	115.6	6		
14	SURATGARH TPS	S	0.49	6.9	9.67	9.7	46.7	0.0	46.7	5		Materialization against the ACQ is more than trigger level
Uttar Pradesh												
15	ANPARA C TPS	P	0.64	10.1	10.15	10.1	215.0	0.0	215.0	21		
16	ANPARA TPS	S	0.65	33.1	22.69	33.1	508.3	0.0	508.3	15		
17	BARKHERA TPS	P	0.80	0.0	0.95	1.0	7.8	0.0	7.8	8		Materialization against the ACQ is more than trigger level
18	DADRI (NCTPP)	C	0.67	12.0	16.20	16.2	370.3	15.5	385.8	24		
19	HARDUAGANJ TPS	S	0.74	0.0	5.92	5.9	199.1	0.0	199.1	34		
20	KHAMBARKHERA TPS	P	0.80	0.0	0.95	1.0	4.2	0.0	4.2	4		Materialization against the ACQ is more than trigger level
21	KUNDARKI TPS	P	0.76	0.0	0.90	0.9	14.2	0.0	14.2	16		
22	LALITPUR TPS	P	0.61	19.9	15.99	19.9	244.9	0.0	244.9	12		
23	MAQSODPUR TPS	P	0.79	0.0	0.94	0.9	14.0	0.0	14.0	15		
24	MEJA STPP	JV	0.67	10.5	11.76	11.8	361.2	0.0	361.2	31		
25	OBRA TPS	S	0.77	9.9	11.09	11.1	120.7	0.0	120.7	11		
26	PARICHHA TPS	S	0.71	11.6	10.72	11.6	245.6	0.0	245.6	21		
27	PRAYAGRAJ TPP	P	0.63	21.1	16.34	21.1	47.5	0.0	47.5	2		Materialization against the ACQ is more than trigger level
28	RIHAND STPS	C	0.64	35.4	25.28	35.4	441.4	0.0	441.4	12		
29	ROSA TPP Ph-I	P	0.66	6.2	10.39	10.4	265.3	0.0	265.3	26		
30	SINGRAULI STPS	C	0.66	28.6	17.45	28.6	405.9	0.0	405.9	14		
31	TANDA TPS	C	0.69	15.2	16.14	16.1	390.8	0.0	390.8	24		
32	UNCHAHAR TPS	C	0.67	18.1	13.65	18.1	196.3	0.0	196.3	11		
33	UTRAULA TPS	P	0.78	0.0	0.93	0.9	11.1	0.0	11.1	12		
Total of Northern Region											0	
Western												
Chhatisgarh												
34	AKALTARA TPS	P	0.64	18.7	15.25	18.7	91.3	0.0	91.3	5		Materialization against the ACQ is more than trigger level
35	BALCO TPS	P	0.71	8.9	5.60	8.9	51.6	17.6	69.2	8		
36	BANDAKHAR TPP	P	0.71	3.7	2.81	3.7	41.5	0.0	41.5	11		
37	BARADARHA TPS	P	0.77	19.8	12.25	19.8	193.5	0.0	193.5	10		
38	BHILAI TPS	JV	0.76	7.3	5.01	7.3	100.6	0.0	100.6	14		
39	BINJKOTE TPP	P	0.75	3.1	5.95	6.0	0.4	0.0	0.4	0		Materialization against the ACQ is more than trigger level
40	DSPM TPS	S	0.69	8.4	4.56	8.4	110.5	0.0	110.5	13		
41	KORBA STPS	C	0.67	39.1	22.94	39.1	252.6	0.0	252.6	6		
42	KORBA-WEST TPS	S	0.78	21.3	13.79	21.3	123.8	0.0	123.8	6		

COAL INDIA LIMITED

MARKETING & SALES DIVISION

COAL STOCK POSITION OF POWER PLANTS HAVING COAL LINKAGE WITH COAL INDIA LIMITED & SCCL AS PER CEA REPORT

Region/State	Name of Thermal Power Station		Specific Coal Consumption (Kcal/kg)	Consumption for last 07 days (Average)*	Requirement @ 55% PLF	Requirement for the day (In '000 Tonnes') (Higher of D and E)	Actual Stock				Status of Criticality as per "New methodology for monitoring of coal stock at coal based thermal power plants" dated 08.11.2017 Critical(*)/Supercritical(**)	Reasons for not considering the plant under critical/super critical category inspite of plant carrying low stock
							In '000 Tonnes'			In Days J=(W/F)		
							Indigenous	Import	Total			
A	B		C	D	E	F	G	H	I	J		
43	LARA TPP	C	0.66	24.0	13.92	24.0	465.4	0.0	465.4	19		
44	NAWAPARA TPP	P	0.79	0.0	6.28	6.3	23.2	0.0	23.2	4		Materialization against the ACQ is more than trigger level
45	PATHADI TPP	P	0.65	8.9	5.18	8.9	109.4	0.0	109.4	12		
46	SIPAT STPS	C	0.68	36.0	26.62	36.0	491.5	0.0	491.5	14		
47	TAMNAR TPP	P	0.84	22.8	26.52	26.5	306.7	0.0	306.7	12		
48	UCHPINDA TPP	P	0.75	16.8	14.22	16.8	92.4	0.0	92.4	5		Materialization against the ACQ is more than trigger level
	Gujarat											
49	GANDHI NAGAR TPS	S	0.69	6.3	5.71	6.3	76.2	0.0	76.2	12		
50	SABARMATI (D-F STATIONS)	P	0.57	3.3	2.74	3.3	59.6	91.9	151.5	46		
51	UKAI TPS	S	0.67	14.6	9.85	14.6	23.3	0.0	23.3	2		Materialization against the ACQ is more than trigger level
52	WANAKBORI TPS	S	0.67	28.1	20.22	28.1	81.4	0.0	81.4	3		Materialization against the ACQ is more than trigger level
	Madhya Pradesh											
53	AMARKANTAK EXT TPS	S	0.65	3.2	1.80	3.2	25.6	0.0	25.6	8		
54	ANUPPUR TPP	P	0.65	18.6	10.31	18.6	183.0	0.0	183.0	10		
55	BINA TPS	P	0.74	3.8	4.88	4.9	19.0	0.0	19.0	4		Materialization against the ACQ is more than trigger level
56	GADARWARA TPP	C	0.66	9.5	13.93	13.9	321.9	54.7	376.6	27		
57	KHARGONE STPP	C	0.60	13.9	10.45	13.9	61.9	0.0	61.9	4		Materialization against the ACQ is more than trigger level
58	SANJAY GANDHI TPS	S	0.82	19.1	14.57	19.1	138.1	0.0	138.1	7		
59	SATPURA TPS	S	0.67	7.1	11.79	11.8	37.0	0.0	37.0	3		Non Payment of Dues
60	SEIONI TPP	P	0.64	3.9	5.06	5.1	137.1	0.0	137.1	27		
61	SHREE SINGAJI TPP	S	0.71	24.0	23.50	24.0	175.0	0.0	175.0	7		Materialization against the ACQ is more than trigger level
62	VINDHYACHAL STPS	C	0.69	57.5	43.60	57.5	927.7	0.0	927.7	16		
	Maharashtra											
63	AMRAVATI TPS	P	0.62	19.0	11.07	19.0	85.0	0.0	85.0	4		Non Payment of Dues
64	BHUSAWAL TPS	S	0.72	16.9	11.44	16.9	132.7	0.0	132.7	8		
65	BUTIBORI TPP	P	0.67	0.0	5.31	5.3	59.7	0.0	59.7	11		
66	CHANDRAPUR(MAHARASHTRA) STPS	S	0.78	38.9	30.17	38.9	86.3	0.0	86.3	2		Non payment of dues
67	DAHANU TPS	P	0.62	5.5	4.09	5.5	2.9	0.0	2.9	1		Materialization against the ACQ is more than trigger level
68	DHARIWAL TPP	P	0.67	8.1	5.34	8.1	25.3	0.0	25.3	3		Materialization against the ACQ is more than trigger level
69	GMR WARORA TPS	P	0.67	7.7	5.29	7.7	0.5	0.0	0.5	0		Materialization against the ACQ is more than trigger level
70	KHAPARKHEDA TPS	S	0.89	7.6	15.72	15.7	199.1	0.0	199.1	13		
71	KORADI TPS	S	0.76	28.7	22.08	28.7	205.1	0.0	205.1	7		
72	MAUDA TPS	C	0.70	14.9	21.29	21.3	691.6	0.0	691.6	32		
73	NASIK TPS	S	0.81	5.6	6.72	6.7	19.0	0.0	19.0	3		Non payment of dues
74	PARAS TPS	S	0.74	7.1	4.90	7.1	26.3	0.0	26.3	4		Non payment of dues
75	PARLI TPS	S	0.67	8.2	6.65	8.2	42.3	0.0	42.3	5		Non payment of dues
76	SOLAPUR STPS	C	0.56	14.1	9.73	14.1	78.1	17.5	95.6	7		
77	TIRORA TPS	P	0.66	41.8	28.73	41.8	248.4	0.0	248.4	6		Materialization against the ACQ is more than trigger level
78	WARDHA WARORA TPP	P	0.66	5.1	4.71	5.1	75.7	0.0	75.7	15		
	Total of Western Region										0	
	Southern											
	Andhra Pradesh											
79	DAMODARAM SANJEEVAIAH TPS	S	0.66	12.7	13.85	13.8	57.6	0.0	57.6	4		Materialization against the ACQ is more than trigger level
80	Dr. N.TATA RAO TPS	S	0.77	19.6	17.90	19.6	149.6	0.0	149.6	8		Materialization against the ACQ is more than trigger level
81	PAINAMPURAM TPP	P	0.59	16.0	10.21	16.0	25.4	46.9	72.3	5		Materialization against the ACQ is more than trigger level
82	RAYALASEEMA TPS	S	0.76	19.0	16.60	19.0	35.0	0.0	35.0	2		Materialization against the ACQ is more than trigger level

COAL INDIA LIMITED

MARKETING & SALES DIVISION

COAL STOCK POSITION OF POWER PLANTS HAVING COAL LINKAGE WITH COAL INDIA LIMITED & SCCL AS PER CEA REPORT

Region/State	Name of Thermal Power Station		Specific Coal Consumption (Kcal/kg)	Consumption for last 07 days (Average)*	Requirement @ 55% PLF	Requirement for the day (In '000 Tonnes') (Higher of D and E)	Actual Stock			In Days	Status of Criticality as per 'New methodology for monitoring of coal stock at coal based thermal power plants' dated 08.11.2017 Critical(*)/Supercritical(**)	Reasons for not considering the plant under critical/super critical category inspite of plant carrying low stock	
							In '000 Tonnes'						
							Indigenous	Import	Total				
A	B		C	D	E	F	G	H	I	J=(I/F)			
83	SIMHADRI	C	0.78	27.8	20.54	27.8	326.8	0.0	326.8	12			
84	SGPL TPP	P	0.53	3.1	9.26	9.3	1.7	153.9	155.6	17			
85	VIZAG TPP	P	0.67	0.0	9.20	9.2	152.3	0.0	152.3	17			
Karnataka													
86	BELLARY TPS	S	0.63	12.5	14.23	14.2	5.4	0.0	5.4	0		Materialization against the ACQ is more than trigger level	
87	KUDGI STPP	C	0.63	14.2	19.90	19.9	236.8	22.5	259.3	13			
88	RAICHUR TPS	S	0.66	12.8	14.98	15.0	203.4	0.0	203.4	14			
89	YERMARUS TPP	S	0.62	15.0	13.09	15.0	23.0	0.0	23.0	2		Materialization against the ACQ is more than trigger level	
Tamil Nadu													
90	METTUR TPS	S	0.81	7.6	8.98	9.0	26.1	0.0	26.1	3		Materialization against the ACQ is more than trigger level	
91	METTUR TPS - II	S	0.78	7.1	6.16	7.1	21.3	0.0	21.3	3		Materialization against the ACQ is more than trigger level	
92	NORTH CHENNAI TPS	S	0.82	16.3	19.78	19.8	165.8	0.0	165.8	8		Materialization against the ACQ is more than trigger level	
93	TUTICORIN TPS	S	0.96	12.5	13.31	13.3	312.9	0.0	312.9	23			
94	VALLUR TPP	JV	0.72	18.5	14.26	18.5	42.8	0.0	42.8	2		Materialization against the ACQ is more than trigger level	
Telangana													
95	BHADRADRI TPP	S	0.69	10.9	7.37	10.9	50.4	0.0	50.4	5		Materialization against the ACQ is more than trigger level	
96	KAKATIYA TPS	S	0.57	13.4	8.33	13.4	284.4	0.0	284.4	21			
97	KOTHAGUDEM TPS (NEW)	S	0.64	8.4	8.46	8.5	119.7	0.0	119.7	14			
98	KOTHAGUDEM TPS (STAGE-7)	S	0.50	8.5	5.23	8.5	122.8	0.0	122.8	15			
99	RAMAGUNDEM STPS	C	0.62	19.8	21.33	21.3	346.1	0.0	346.1	16			
100	RAMAGUNDEM-B TPS	S	0.77	0.8	0.63	0.8	7.4	0.0	7.4	9			
101	SINGARENI TPP	S	0.58	15.5	9.12	15.5	146.9	0.0	146.9	9			
Total of Southern Region											0		
Eastern													
Bihar													
102	BARAUNI TPS	C	0.63	5.6	5.90	5.9	60.3	0.0	60.3	10			
103	BARH I	C	0.67	7.4	5.84	7.4	119.2	0.0	119.2	16			
104	BARH II	C	0.67	15.1	11.67	15.1	238.5	0.0	238.5	16			
105	KAHALGAON TPS	C	0.80	28.1	24.62	28.1	98.8	0.0	98.8	4		Materialization against the ACQ is more than trigger level	
106	MUZAFFARPUR TPS	JV	0.77	5.1	6.18	6.2	92.5	0.0	92.5	15			
107	NABINAGAR STPP	JV	0.58	16.7	10.14	16.7	233.4	0.0	233.4	14			
108	NABINAGAR TPP	JV	0.69	12.4	9.06	12.4	62.1	0.0	62.1	5		Materialization against the ACQ is more than trigger level	
Jharkhand													
109	BOKARO TPS `A` EXP	C	0.57	5.2	3.78	5.2	127.1	0.0	127.1	24			
110	CHANDRAPURA(DVC) TPS	C	0.61	6.8	4.06	6.8	123.6	0.0	123.6	18			
111	JOJOBERA TPS	P	0.69	3.0	2.18	3.0	79.3	0.0	79.3	26			
112	KODARMA TPP	C	0.62	7.1	8.23	8.2	62.8	0.0	62.8	8		Materialization against the ACQ is more than trigger level	
113	MAHADEV PRASAD STPP	P	0.70	7.8	5.01	7.8	14.4	0.0	14.4	2		Materialization against the ACQ is more than trigger level	
114	MAITHON RB TPP	P	0.64	10.5	8.89	10.5	193.3	0.0	193.3	18			
115	TENUGHAT TPS	S	0.75	4.7	4.16	4.7	34.8	0.0	34.8	7		Materialization against the ACQ is more than trigger level	
Odisha													
116	DARLIPALI STPS	C	0.71	13.7	14.95	15.0	489.6	0.0	489.6	33			
117	DERANG TPP	P	0.70	15.3	11.10	15.3	556.0	0.0	556.0	36			
118	IB VALLEY TPS	S	0.83	18.9	19.16	19.2	399.3	0.0	399.3	21			
119	KAMALANGA TPS	P	0.72	17.5	10.02	17.5	105.2	0.0	105.2	6			
120	VEDANTA TPP	P	0.76	7.9	6.02	7.9	3.5	0.0	3.5	0		Materialization against the ACQ is more than trigger level	
121	TALCHER STPS	C	0.79	37.1	31.43	37.1	549.0	0.0	549.0	15			

COAL INDIA LIMITED
MARKETING & SALES DIVISION
COAL STOCK POSITION OF POWER PLANTS HAVING COAL LINKAGE WITH COAL INDIA LIMITED & SCCL AS PER CEA REPORT

Region/State	Name of Thermal Power Station		Specific Coal Consumption (Kcal/kg)	Consumption for last 07 days (Average)*	Requirement @ 55% PLF	Requirement for the day (In '000 Tonnes') (Higher of D and E)	Actual Stock			In Days	Status of Criticality as per "New methodology for monitoring of coal stock at coal based thermal power plants" dated 08.11.2017 Critical(*)/Supercritical(**)	Reasons for not considering the plant under critical/super critical category inspite of plant carrying low stock
							In '000 Tonnes'					
							Indigenous	Import	Total			
A	B		C	D	E	F	G	H	I	J=(I/F)		
West Bengal												
122	BAKRESWAR TPS	S	0.62	14.5	8.61	14.5	78.9	0.0	78.9	5		
123	BANDEL TPS	S	0.78	3.8	3.39	3.8	11.0	0.0	11.0	3		Materialization against the ACQ is more than trigger level
124	BUDGE BUDGE TPS	P	0.58	5.3	5.77	5.8	128.8	0.0	128.8	22		
125	D.P.L. TPS	S	0.68	6.7	4.90	6.7	14.5	0.0	14.5	2		Materialization against the ACQ is more than trigger level
126	DURGAPUR STEEL TPS	C	0.69	14.3	9.16	14.3	37.5	0.0	37.5	3		Materialization against the ACQ is more than trigger level
127	DURGAPUR TPS	C	1.06	0.0	2.93	2.9	58.2	0.0	58.2	20		
128	FARAKKA STPS	C	0.70	25.4	19.34	25.4	47.3	0.0	47.3	2		Materialization against the ACQ is more than trigger level
129	HALDIA TPP	P	0.67	7.6	5.29	7.6	19.5	0.0	19.5	3		Materialization against the ACQ is more than trigger level
130	HIRANMAYE TPP	P	0.72	5.2	2.83	5.2	34.6	0.0	34.6	7		
131	KOLAGHAT TPS	S	0.75	9.7	12.49	12.5	13.9	0.0	13.9	1		Materialization against the ACQ is more than trigger level
132	MEJIA TPS	C	0.68	28.1	21.12	28.1	161.6	0.0	161.6	6		Materialization against the ACQ is more than trigger level
133	RAGHUNATHPUR TPP	C	0.64	12.8	10.16	12.8	94.2	0.0	94.2	7		
134	SAGARDIGHI TPS	S	0.61	23.2	12.93	23.2	71.2	0.0	71.2	3		Materialization against the ACQ is more than trigger level
135	SANTALDIH TPS	S	0.70	8.5	4.64	8.5	48.0	0.0	48.0	6		
136	SOUTHERN REPL. TPS	P	0.75	0.3	1.34	1.3	9.4	0.0	9.4	7		Plant diverting coal to the other plants
Total of Eastern Region											0	
North Eastern												
Assam												
137	BONGAIGAON TPP	C	0.58	7.5	5.79	7.5	86.8	0.0	86.8	12		
Total of North Eastern Region											0	
Total Coal Stock			0.69	1750.4	1507.89	1890.6	20302.5	420.5	20723.0	11	0	

Note

1. https://cea.nic.in/wp-content/uploads/2020/04/guidelines_dcr.pdf	←	Link for New Methodology dated 08.11.2017
2. % Materialization against ACQ is taken from 01.04.21 to 07.12.2021		
3. Plant wise Specific Coal Consumption = (Coal Requirement @85% PLF*1000)/(Capacity*24*0.85)- Source:- Daily coal stock report, CEA		
4. List of Linked Plants with CIL taken from the Daily Coal Report of CEA showing status as on 13.12.2021		